

CERTIFICATE OF CONFORMITY – WATER BASED FIRE EXTINGUISHING MEDIA

Certificate of conformity reference number: **KB 185/14**

Test specification: Test procedure LM 01-01, Nov. 29, 2011, test of water based fire extinguishing media except for clause 4.11 – packaging, marking, see the note below

Test report no.: 20140916

Requested by: BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA

Manufacturer: BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA

Product name: Bonpet fire-extinguishing liquid

Type of fire extinguishing medium: Fluid fire extinguishing medium (readymade solution)

Test fire performance: Proof with portable EN 3 fire extinguishers:
27 A according to EN 3-7 with 6 litres fire extinguishing medium
144 B according to EN 3-7 with 6 litres fire extinguishing medium
75 F according to EN 3-7 with 6 litres fire extinguishing medium

Freezing point: -14,5 °C

Notes:

1. The fire extinguishing medium is to use undiluted.
2. The information according to clause 4.11 of LM 01-01 for marking shall be stated on the packing or on the storage container.


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for fire extinguishing media which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

26th August, 2014


Grad. Eng. Jürgen Dittrich
Laboratory Manager

